

COMPONENT SHEET
K-1650 COMBINATION BOILER/COOLING SYSTEM

COMPONENTS:

P/T Alkalinity

- 1 x 5213
- *1 x 9198
- *1 x R-0638G-C
- 1 x R-0645-C
- *1 x R-0736-C

Instruction

Sample Tube, Graduated (25 mL) w/ cap, plastic
Phenolphthalein Indicator, 2 oz w/ green cap, DB
Total Alkalinity Indicator, 2 oz, DB
Sulfuric Acid .6N, 2 oz, DB

Chloride

- 1 x 5212
- *1 x 9198
- 1 x R-0630-C
- *1 x R-0638G-C
- 1 x R-0706-C
- *1 x R-0736-C

Instruction

Sample Tube, Graduated (25 mL) w/ cap, plastic
Chromate Indicator, 2 oz, DB
Phenolphthalein Indicator, 2 oz w/ green cap, DB
Silver Nitrate Reagent, 2 oz, DB
Sulfuric Acid .6N, 2 oz, DB

Orthophosphate

- 2 x 2269
- 1 x 4027
- 1 x 5210
- 1 x 6003
- 1 x 6009
- 1 x 9021

- 1 x 9025

- 2 x R-0601-C
- 1 x R-0602P-I

Cap, Dispenser, 18 mm, white
Funnel, 58 mm, plastic
Instruction
Brush, Test Tube
Filter Paper, 9.0 cm, #610, 100/box
Test Tube, Mixing, Calibrated (5, 10, 14, 15, 17.5 mL),
glass w/ stopper
2-Standard Comparator, Orthophosphate, Stannous
Chloride, 30 & 60 ppm
Molybdate Reagent, 2 oz
Stannous Chloride Powder, 10 g

Instr. #5068

Sodium Sulfite

- 1 x 5203
- *1 x 9198
- *1 x R-0638G-C
- 1 x R-0699-C
- 1 x R-0725-I

Instruction

Sample Tube, Graduated (25 mL) w/ cap, plastic
Phenolphthalein Indicator, 2 oz w/ green cap, DB
Iodide Iodate Reagent, 2 oz, DB
Acid Starch Indicator Powder, 10 g

Misc.

- 1 x 5068
- *Kit includes one.

Instruction (Component Sheet)

TO ORDER REPLACEMENT PARTS AND REAGENTS CALL TOLL-FREE
800-TEST KIT (800-837-8548).



31 Loveton Circle, Sparks, MD 21152 USA
800-TEST KIT (837-8548) • 410-472-4340

110217